



Lee County

Contaminant	Number of wells tested	Minimum	Maximum	Average	Maximum Contaminant Level (MCL) * Secondary MCL	Units	Number of wells tested above MCL	Percentage of wells tested above MCL	Number of wells below MCL	Percentage of wells tested below MCL
1,2-Dibromoethane	Not Tested	0	0	0	0.05	µg/L	0	Not Tested		
1,2-Dichloropropane	Not Tested	0	0	0	5	µg/L	0	Not Tested		
Arsenic	122	0.5	20	1.9	10	µg/L	1	0.82%		
Barium	28	50	50	50	2,000	µg/L	0	0.00%		
Benzene	Not Tested	0	0	0	5	µg/L	0	Not Tested		
Cadmium	29	0.5	2.5	0.7	5	µg/L	0	0.00%		
Chromium	28	5	20	5.5	100	µg/L	0	0.00%		
cis-1,2-Dichloroethene (c-DCE)	1	0.25	0.25	0.25	70	µg/L	0	0.00%		
Copper	122	25	3,910.00	119.30	1,300*	µg/L	2	1.64%		
Ethylbenzene	Not Tested	0	0	0	700	µg/L	0	Not Tested		
Fluoride	453	100	1,590.00	695.80	4,000*	µg/L	0	0.00%		
Iron	120	25	13,250.00	534.00	300*	µg/L	29	24.17%		
Isopropyl Ether	Not Tested	0	0	0	No drinking water standard	µg/L				
Lead	155	2.5	48	3.9	15	µg/L	6	3.87%		
Magnesium	123	11,900	119,700.00	18,685.40	No drinking water standard	µg/L				
Manganese	122	15	1,300.00	110.10	50*	µg/L	44	36.07%		

Contaminant	Number of wells tested	Minimum	Maximum	Average	Maximum Contaminant Level (MCL) * Secondary MCL	Units	Number of wells tested above MCL	Percentage of wells tested above MCL	Number of wells below MCL	Percentage of wells tested below MCL
Mercury	27	0.3	0.3	0.3	2	µg/L	0	0.00%		
Methyl tertiary butyl ether (MTBE)	1	0.25	0.25	0.25	20* (recommended taste and odor threshold)	µg/L	0	0.00%		
Nitrate	23	500	4,000.00	837.00	10,000	µg/L	0	0.00%		
Nitrite	23	50	50	50	1,000	µg/L	0	0.00%		
pH	122	4.8	8.7	7.03	6.5-8.5*	standard units	1	0.82%	26	21.31%
Selenium	28	2.5	2.5	2.5	50	µg/L	0	0.00%		
Silver	28	25	25	25	100*	µg/L	0	0.00%		
Sodium	25	2,000	133,000.00	14,184.00	No drinking water standard	µg/L				
Tetrachloroethylene (PCE)	1	0.25	0.25	0.25	5	µg/L	0	0.00%		
Toluene	Not Tested	0	0	0	1,000	µg/L	0	Not Tested		
trans-1,2-Dichloroethene (t-DCE)	1	0.25	0.25	0.25	100	µg/L	0	0.00%		
Trichloroethylene (TCE)	1	0.25	0.25	0.25	5	µg/L	0	0.00%		
Vinyl chloride	1	0.25	0.25	0.25	2	µg/L	0	0.00%		
Xylenes (Total)	Not Tested	0	0	0	10,000	µg/L	0	Not Tested		
Zinc	121	25	1,890.00	163.70	5,000*	µg/L	0	0.00%		

* **Secondary MCL:** Secondary contaminants may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water.⁸ The **Secondary Maximum Contaminant Level (SMCL)** is a non-enforceable standard for secondary contaminants in drinking water. SMCLs may be based upon a contaminant's likelihood to cause changes to the taste, odor, or color of drinking water, or, may be based on the likelihood of the contaminant to cause technical changes such as damage to water fixtures or an increased availability of other contaminants in drinking water.⁸

Tracking and Analyzing Contaminants (TrAC) in Private Well Water in NC
UNC Superfund Research Program- Research Translation Core
Funded by an ARRA supplement from NIEHS (P42-ES005948) 2009-2011

